

Certificate of constancy of performance for product

0679-CPR-0200

(English translation, the original version is in French)

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 march 2011 laying down harmonised conditions for the marketing of construction products and repealing Council Directive 89/106/EEC, it has been stated that the construction products indicated in the following page, placed on the European economic area market by :

MANUFACTURE FRANÇAISE DES ARDENNES

2 bis avenue François Sommer
BP 60065 Glaire
08206 SEDAN CEDEX
FRANCE

and produced in the factory:

MANUFACTURE FRANÇAISE DES ARDENNES
2 bis avenue François Sommer - BP 60065 Glaire
08206 SEDAN CEDEX – FRANCE

are submitted by the manufacturer to a factory production control and to the further testing of samples taken of the factory in accordance with a prescribed test plan and that the notified body - CSTB - has performed the assessment of performance of fire reaction of construction products, the initial inspection of the manufacturing plant and of the factory production control and performs the continuous surveillance, assessment and evaluation of the factory production control (system 1).

This certificate attests to the products performance of fire reaction and that all provisions concerning the assessment and verification of constancy of performance described in the harmonized reference technical specification:

EN 14041 : 2004

Are applied and that the products fulfill all the prescribed requirements.

Products fire reaction performance: B_{f1} – s1, valid when loose or bonded to any A2-s1,d0 or A1 rated substrate whose thickness is ≥ 6 mm and whose density is ≥ 1350 kg/m³.

This certificate can only be used in conjunction with the declaration of performance of the products written by the manufacturer or his authorised representative established in the European economic area and with the technical specification in reference.


This certificate is issued on 10th of December 2015, it cancels and replaces the certificate previously delivered on 5th of March 2015 and, except for withdrawal or suspension, remains valid as long as the conditions laid down in the corresponding technical specification in reference or the manufacturing conditions in the factory or the factory production control itself are not modified significantly.

This certificate comprises 2 pages.

The list of certificates issued by CSTB is kept up-to-date by the CSTB.

Issued in Champs sur Marne, on 10th of December 2015

For CSTB
On behalf of the Technical Director


Yannick LEMOIGNE

Products

TAPISOM 810 PLAQUE
TAPISOM MODUL
TAPISOM XL 21

Product type :

Textile needed floor covering in tiles with PA/PP/PES use surface on PVC backing.

Use category :

Internal use as floor covering