

(English translation, the original version is in French)

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 march 2011 laying down harmonised conditions for the marketing of construction products and repealing Council Directive 89/106/EEC, it has been stated that the construction product indicated in the following page, placed on the European economic area market by :

MANUFACTURE FRANÇAISE DES ARDENNES

2 bis avenue François Sommer
BP 60065 Glaire
08206 SEDAN CEDEX
FRANCE

and produced in the factory:

MANUFACTURE FRANÇAISE DES ARDENNES
2 bis avenue François Sommer - BP 60065 Glaire
08206 SEDAN CEDEX - FRANCE

Is submitted by the manufacturer to a factory production control and to the further testing of samples taken of the factory in accordance with a prescribed test plan and that the notified body - CSTB - has performed the assessment of performance of fire reaction of construction product, the initial inspection of the manufacturing plant and of the factory production control and performs the continuous surveillance, assessment and evaluation of the factory production control (system 1).

This certificate attests to the product performance of fire reaction and that all provisions concerning the assessment and verification of constancy of performance described in the harmonized reference technical specification:

EN 14041 : 2004

Are applied and that the product fulfills all the prescribed requirements.

Product fire reaction performance: C_n - s1, valid when bonded to any A2-s1,d0 or A1 rated substrate whose thickness is ≥ 6 mm and whose density is ≥ 1350 kg/m³.

This certificate can only be used in conjunction with the declaration of performance of the product written by the manufacturer or his authorised representative established in the European economic area and with the technical specification in reference.


This certificate is issued on 10th of December 2015, it cancels and replaces the certificate previously delivered on 3rd of March 2015 and, except for withdrawal or suspension, remains valid as long as the conditions laid down in the corresponding technical specification in reference or the manufacturing conditions in the factory or the factory production control itself are not modified significantly.

This certificate comprises 2 pages.

The list of certificates issued by CSTB is kept up-to-date by the CSTB.

Issued in Champs sur Marne, on 10th of December 2015

For CSTB
On behalf of the Technical Director


Yannick LEMOIGNE

Products :

TECSOM 3630s SUPREME ACOUSTIQUE SPECIAL
TECSOM 3630S SUPREME ACOUSTIQUE
TECSOM 2050 PREMIUM ACOUSTIQUE
TECSOM PRIMA ACOUSTIQUE
TECSOM CAMERA ACOUSTIQUE
TECSOM 2500 NORDIC ACOUSTIQUE
TECSOM 3550 LINEAR VISION ACOUSTIQUE
TECSOM 3580 CITY SQUARE ACOUSTIQUE
TECSOM 3600 GREEN SYSTEM ACOUSTIQUE
TECSOM 3620 POINTE ACOUSTIQUE
TECSOM 3800 CROSS ACOUSTIQUE

Product type :

Tufted textile floor covering in tiles with 100% polyamid loop pile on PVC backing with textile reinforced bottom in polyester.

Use category :

Internal use as floor covering